

**Please answer the following questions and return this form to Termaco via this email address:
cabinets@termaco.com**

Are you familiar with STD Termaco Top Terminal Battery Cabinet series:

Yes No

Please provide the following information regarding the UPS:

- Input Voltage: _____ VDC

Please complete either one of the following subsections:

- kVA, Power Factor (PF) and efficiency of the UPS: _____ kVA;
_____ PF; _____ % Efficiency

or

- kW and efficiency of the UPS: _____ kW; _____ % Efficiency

Confirm the desired cabinet configuration:

- Do you need a specific height (UPS matching cabinet):

No particular height needed (STD version)

Yes. Please specify desired height: _____ inches

- Number of batteries per tier: _____

- Number of tiers: _____

- Front configuration: Removable front panel Hinged Door(s)

Please indicate the breaker amperage required: _____ Amp.

Do you know the manufacturer of the batteries
intended to be used in this cabinet:

Yes. Please indicate battery manufacturer: _____

No. Indicate your preferred battery manufacturer (if any): _____

171, Tuckerton Road
Reading, PA
19605 United States
325, boul. Industriel
Saint-Jean-sur-Richelieu (Qc)
J3B 7M3 Canada

T 450 346.6871
F 450 346.4368
TOLL FREE
1 800 363.1964

If you know, please indicate the model of battery intended to be used in this cabinet (Optional):

- Model of Battery/Cell: _____
- Quantity of Batteries/Cells per Cabinet: _____
- Battery/Cell Dims (Length, Depth, Height): _____ L x _____ D x _____ H
- Battery/Cell Weight (Lbs or Kg): _____ Lbs / or _____ Kg

If a "Custom" cabinet is required, please fill all applicable fields below:

- Footprint available: _____
- Maximum height of cabinet: _____
- UL certification required: Yes No

Select the seismic rating desired:

- Low seismic rating (IBC 2015, 0.21g ground level)
- Seismic rating (IBC 2015, Sds = 1.38g top of building, Sds = 1.55g ground level)
- NEBS Zone 4 Construction
- NEBS Zone 4 (Test Passed) (only available for TCR-CS-410RB at 78,7" H)
- OSHPD certified (only available for TCR-CS-410RB at 78,7" H)
- OSHPD construction

Select desired color:

Black Beige White Grey

Other (Please specify): _____

UPS Model: _____

Powder coat color code: _____

Choose your cabinet options:

- "Close to wall" anchoring (not available for NEBS)
- NEMA 2 construction
- Lifting Eyebolts
- Busbars (for output connections, behind the breaker).
- Charger: UL (up to 240VDC) Not UL (240VDC and above) Deselect
- Shunt or UVR Breaker Accessories: UVR Shunt Trip Deselect
- Auxiliary Breaker Accessories



171, Tuckerton Road
Reading, PA
19605 United States

325, boul. Industriel
Saint-Jean-sur-Richelieu (Qc)
J3B 7M3 Canada

T 450 346.6871
F 450 346.4368
TOLL FREE
1 800 363.1964